



Republic of the Philippines  
DEPARTMENT OF PUBLIC WORKS AND HIGHWAYS  
OFFICE OF THE SECRETARY  
Manila

11.0 MAY 2018

MEMORANDUM

FOR : Secretary MARK A. VILLAR  
Secretary  
This Department

This refers to the Memorandum dated 27 April 2018 of **DPWH Region XI Regional Director ALLAN S. BORROMEO, CESO IV**, endorsing the request of District Engineer Joselito B. Caballero, Compostela Valley DEO, for the approval of the Modification of the hereunder project for FY 2018 General Appropriation Act (GAA), to wit:

As per GAA/Original			As Modified		
Project Description					
<b>UACS No. 320101102270000</b> <b>Project ID: P00220203MN</b>					
OO2: Protect Lives and Properties			OO2: Protect Lives and Properties		
Flood Management - Construction/ Maintenance of Flood Mitigation Structures and Drainage Systems			Flood Management - Construction/ Maintenance of Flood Mitigation Structures and Drainage Systems		
Construction of Revetment, Brgy. Napnapan, Pantukan, Compostela Valley			Construction of Revetment, Brgy. Napnapan, Pantukan, Compostela Valley		
Physical Target	Unit Cost (P'000)	Allocation (P'000)	Physical Target	Unit Cost (P'000)	Estimated Cost (P'000)
CW-1 – Construction of Revetment: 1,050 Lineal meters	P 30.22/ Lineal meter	P 31,734.487	CW-1 – Construction of Revetment: 687.28 Lineal meters	P 47.35/ Lineal meter	P 32,540.50
CW-2 – Channelization: 3,500 cubic meters	P 0.62/ cubic meter	P 2,163.713	CW-2 – Channelization: 1,463 cubic meters	P 0.93/ cubic meter	P 1,357.70
ROW- ROW Acquisition: 2,343 square meters	P 0.17/ square meter	P 401.80	ROW- ROW Acquisition: 2,343 square meters	P 0.17/ square meter	P 401.80
EAO	-	700.00	EAO	-	700.00
Total:		P 35,000	Total:		P 35,000
<b>Justification:</b> <u>Decrease in physical target :</u> For the length of revetment from 1,050.00 m. to 687.28 m. due to the following: <ul style="list-style-type: none"><li>The proposed alignment of the revetment lies on the eroded parts of the riverbank thus embankment works is needed.</li><li>The height of the structure as per design requires higher elevation than anticipated height, from 4m to 6m.</li></ul> For volume of channelization from 3,500.00 cu.m. to 1,463.00 cu.m. since excavated materials will be utilized as embankment for the revetment.					

Based on our evaluation, the herein request is found in order, hence approval is hereby recommended.

**RAFAEL C. YABUT**  
Senior Undersecretary  
Undersecretary for Mindanao Regional Operations

APPROVED/DISAPPROVED:

**MARK A. VILLAR**  
Secretary

**DIMAS S. SOGUILON**  
Undersecretary  
Officer-In-Charge

2.1 MSQ/ACF/RCY

Department of Public Works and Highways  
Office of the Secretary



WIN8C02978