



DEPARTMENT OF PUBLIC WORKS AND HIGHWAYS  
**OFFICE OF THE SECRETARY**  
Manila

29 JUN 2018

**MEMORANDUM**

**FOR :** Secretary **MARK A. VILLAR**  
Secretary  
This Department

This refers to the Memorandum dated 21 June 2018 of **DPWH XI Regional Director ALLAN S. BORROMELO, CESO IV**, endorsing the request of OIC-District Engineer Cynthia Grace C. Tiu, Davao Oriental 2<sup>nd</sup> DEO, for the approval of the Modification of the hereunder project for FY 2018 General Appropriation Act (GAA), to wit:

As per GAA/Original			As Modified		
Project Description					
<b>UACS No. 300203100604000</b> <b>Project ID: P00230142MN</b>					
Convergence and Special Support Program			Convergence and Special Support Program		
Convergence and Special Support - Construction/Improvement of Access Roads leading to Declared Tourism Destinations			Convergence and Special Support - Construction/Improvement of Access Roads leading to Declared Tourism Destinations		
Jct. La Union – Mt. Hamiguitan Road leading to Mt. Hamiguitan, San Isidro, Davao Oriental			Jct. La Union – Mt. Hamiguitan Road leading to Mt. Hamiguitan, San Isidro, Davao Oriental		
Physical Target	Unit Cost (P'000)	Allocation (P'000)	Physical Target	Unit Cost (P'000)	Estimated Cost (P'000)
CW-1 – Construction of Concrete Road: 1.200 Lane Km	P 16,333.33/ Lane Km	P 19,600.00	CW-1 – Construction of Road Slope Protection Structure: 800 sq. m.	P 24.50/ sq. m.	P 19,600.00
EAO	-	P 400.00	EAO	-	P 400.00
Total:		P 20,000.00	Total:		P 20,000.00
<b>Justification:</b> Change in scope of work from road concreting of 1.200 Lane Km to construction of road slope protection with a length of 200 lm and a total area of 800 sq. m. due to the following:					
<ul style="list-style-type: none"><li>Original proposal includes paying the gap portion of the road section with concrete pavement. However, during the actual validation, there is an urgent need for construction of slope protection structure due to the existing landslide on said section in order to prioritize the safe access leading to tourist destination.</li><li>Work includes installation of gabions with a total area of 800 sq. m., to address the sudden erosion on said section during heavy rains.</li></ul>					

Based on our evaluation, the herein request is found in order, hence approval is hereby recommended.

**RAFAEL C. YABUT**

Senior Undersecretary  
Undersecretary for Mindanao Regional Operations

**APPROVED/DISAPPROVED:**

**MARK A. VILLAR**  
Secretary

2.1 MSQ/ACF/RCY

Department of Public Works and Highways  
Office of the Secretary



WIN8C03312